





NOTES

- 1. Wiring between ballast box and nearest fixture and between fixtures shall be run in 16C, Type 4 conduit.
- 2. Conduit shall be secured to nearest member using one-hole agivanized maliable iron or steel straps at 1.5 m maximum centers and brass machine screws tapped into the member.
- 3. Ballasts and terminal boards shall be marked with legible symbols. Conductors shall be tagged and their identification marked on the corresponding terminal on the terminal board as shown on the Typical Fixture Wiring Diagram. An alternative cover design shall be submitted for approval.
- 4. Ballast shall be one, two or three lamp types as required, 5. Each ballast shall be fused with 32 mm x 6 mm slow-blow
- glass tube fuse. 6. Fuseholder shall be a panel mounted type, with screw type
- finger knob.
- At the option of the Contractor, the fixture may be supplied with an integral ballast. The ballast box will not be required when fixtures with integral ballasts are

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

ELECTRICAL SYSTEMS (915 mm FLUORESCENT SIGN **ILLUMINATION EQUIPMENT)**

NO SCALE

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN ES-15B